CBGS

27/5/15

QP Code: 3492

(3 Hours)

[Total Marks: 80

- N.B. (1) Question No. 1 is compulsory.
 - (2) Attempt any three questions from remaining.
 - (3) Figures on right indicate full marks.
- 1. (a) Write the parameters that can be calculated by using open circuit and short 20 circuit test in transformer.
 - (b) List the advantages of Hopkinson's test.
 - (c) What are the various losses in transformer?
 - (d) State the methods to minimize armature reaction.
- 2. (a) Explain different electrical braking methods for seperately excited D.C. motor. 10
 - (b) Derive the expression for electromagnetic torque for doubly exited system in terms of angular rate of charge of self and mutual inductance of stator and rotor winding.
- 3. (a) Compare the two winding transformer with auto transformer and derive the 10 expression of copper soving in autotransformer.
 - (b) The Hopkinonson's test on two shunt gave the following result for full load: 10
 - (i) Line voltage

= 250v

- (ii) Current taken from supply system excluding field current = 50amp
- (iii) Motor armature current

=380 amp

(iv) field currents 5 amp and 4.2 amp.

Calculate efficiency of the machine working as an generator and motor assume armature resistance of each machine is 0.02Ω .

- 4. (a) Two single phase transformer rated at 500 KVA and 450 KVA respectively are 10 connected in parallel to supply a load of 1000 KVA at 0.8 p.f. lagging. The per unit resistance and per unit leadkye reactance of first transformer are 2.5% and 6% respectively and second transformer 1.6% and 7% respectively. Calcualte the KVA load and power factor at which each transformer operates.
 - (b) Explain the characteristics of DC shunt and series motor.

10

2

(a) A 4KVA, 200/400V, 50 Hz single phase transformer gave the following test 10 results

O.C. test: 200V, 0.7A, 60w (L.V. side)

S.C. test: 9V, 6A, 21.6W (H.V. side)

Calculate (i) The efficiency and voltage regulation at full load 0.8 pf. lagging.

- (ii) The efficiency at half load at unity power factor.
- (b) Draw phase diagram for single phase transformer for lagging and leading power 10 factor.
- 6. (a) Explain the armature reaction in D.C. machine.

 10

 (b) Explain 3 point starter and also explain advantages of 4 point starter over it.
 - (b) Explain 3 point starter and also explain advantages of 4 point starter over it. 10